

# Copy of the certificate regarding Water, Health & Sanitation issued by Medical Officer, Urban Health Centre, Chandlodia

Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 17<sup>th</sup> Feb'24

It is certified that an inspection team headed by Ms. Ruchi Patel, Medical Officer from Chandlodia Urban Health Center PHED inspected the **H3 WORLD SCHOOL, SUB PLOT 2 & 3, SURVEY NO - 259 TP. NO. 233, FP NO. 54, NEAR DUTT PARISAR, TRAGAD GAM ROAD, TRAGAD, AHMEDABAD, GUJARAT 382470** on 15<sup>th</sup> Feb'24 and on the basis of Water Test Report (Attached) bearing no: - dated 20<sup>th</sup> Sept'23 of Central Laboratory (PHED Lab) certified that the H3 WORLD SCHOOL has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

This certificate is valid till 20<sup>th</sup> Sept'25

Signature with Seal: 

Name: Ms. Ruchi Patel

Designation: Medical Officer  
Urban Health Center

Name & Address of the Office/ Department: Chandlodia

To:

H3 WORLD SCHOOL,  
SUB PLOT 2 & 3, SURVEY NO - 259  
TP. NO. 233, FP NO. 54,  
NEAR DUTT PARISAR,  
TRAGAD GAM ROAD, TRAGAD,  
AHMEDABAD, GUJARAT-382470

Note: The certificate is to be issued by authorized officer/ PHED Lab/ local bodies

  
PRINCIPAL  
H3 WORLD SCHOOL  
TRAGAD, AHMEDABAD

FOR, H3 WORLD SCHOOL, TRAGAD  
Ravesh chandra Bagan  
(Director/Authorised Signatory)

# Copy of the Water Examination Report



AHMEDABAD MUNICIPAL CORPORATION  
MAHANAGAR SEVA SADAN  
**CENTRAL LABORATORY**  
(An ISO 9001: 2015 Accredited Laboratory)



Lic No QAC/R91/1650

Dudheshwar Water Works Compound, Dudheshwar, Ahmedabad-380 004, Gujarat, India  
E-mail: centrallab@ahmedabodcity.gov.in, Phone No-(079) 25631105, 25630438.

September 20 2023.

To,  
The Principal,  
H 3 World School (Tragad Campus)  
Sub Plot - 2, Survey No. 259, Nr. Dutt Parisar,  
Tragad, Ahmedabad - 382470.

Dear Sir,

We have analyzed your water samples collected on Dt. 14-09-2023 for the following **Chemical and Bacteriological** parameters. The analysis report is as hereunder.

Sr. No.	Parameter	Requirement (Acceptable Limit)	Permissible Limit in the Absence of Alternate Source	Sample Value
		As per IS-10500-2012		
<b>A. Organoleptic and Physical Parameters</b>				
1	Colour, Hazen units, Max	5	15	0.1
2	pH value	6.5-8.5	No relaxation	7.85
3	Turbidity, NTU, Max	1	5	0.1
4	Total dissolved solids, mg/l, Max	500	2000	258
<b>B. General Parameters</b>				
1	Total hardness (as CaCO <sub>3</sub> ), mg/l, Max	200	600	50
2	Calcium (as Ca), mg/l, Max	75	200	12
3	Magnesium (as Mg), mg/l, Max	30	100	4.88
4	Chloride (as Cl), mg/l, Max	250	1000	60
5	Sulphate (as SO <sub>4</sub> ) mg/l, Max	200	400	5.3
6	Total alkalinity (as CaCO <sub>3</sub> ), mg/l, Max	200	600	130
7	Free residual chlorine, mg/l, Min	0.2	1.0	Nil
<b>C. Bacteriological Quality of Drinking Water</b>				
1	Total Coliform bacteria, MPN/100 ml.	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	Not Detectable
2	E. coli, MPN/100 ml.	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	Not Detectable

**Remarks:**

- The Central Laboratory, AMC, has collected the samples.
- The result contained in this report relate only to the sample material tested.
- The report is not being reproduce wholly or in part and cannot be used as evidence in the court of law and should not be used in any advertising media without our special permission in writing.
- The above chemical and bacteriological parameter's values are not in excess of acceptable limit, Hence sample is fit for drinking purpose.

NOTE — It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned under 'acceptable' render the water not suitable, but still 'permissible limit in the absence of alternate source' in column 4, above which the sources will have to be rejected. May be tolerated in the absence of an alternative source but up to the limits indicated.

*Joshi*  
Medical Officer  
Urban Health Center  
Chandiodia

*2019/09/23*  
Scientist In-Charge  
Central Laboratory

*B.*  
PRINCIPAL  
H3 WORLD SCHOOL  
TRAGAD, AHMEDABAD

FOR, H3 WORLD SCHOOL, TRAGAD  
*Ravish Chandra Bagan*  
(Director/Authorised Signatory)