

Copy of the certificate regarding Water, Health & Sanitation issued by
Medical Officer, Urban Health Centre, Chandlodia


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 17th Sept '25

It is certified that an inspection team headed by Ms. Ruchi Patel, Medical Officer
from Chandlodia, Urban Health Center PHED
inspected the H3 WORLD SCHOOL, SUB PLOT 2 & 3, SURVEY NO - 259 TP. NO. 233, FP NO. 54, NEAR DUTT
PARISAR, TRAGAD GAM ROAD, TRAGAD, AHMEDABAD, GUJARAT 382470 on 17th Sept '25
and on the basis of Water Test Report (Attached) bearing no: —
dated 15th Sept '25 of Central Laboratory A.M.C. (PHED Lab) certified that
the H3 WORLD SCHOOL has safe drinking water facilities for the students and members of staff of the
institution. School is also maintains the hygienic sanitation condition in the school building & the campus as
per norms prescribed by the Central/State/U.T. Govt.

This certificate is valid till 17th Sept '26

Signature with Seal: 

Name: Medical Officer

Designation: Urban Health Center

Chandlodia

Name & Address of the Office / Department:

.....

To:

H3WORLD SCHOOL,
SUBPLOT 2&3, SURVEY NO- 259
TP.NO.233, FPNO.54, NEAR
DUTT PARISAR,
TRAGAD GAM ROAD, TRAGAD,
AHMEDABAD, GUJARAT-382470

Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies



AHMEDABAD MUNICIPAL CORPORATION
MAHANAGAR SEVA SADAN
CENTRAL LABORATORY
(An ISO 9001: 2015 Accredited Laboratory)



Dudheshwar Water Works Compound, Dudheshwar, Ahmedabad-380 004, Gujarat, India
E-mail: centrallab@ahmedabadcity.gov.in, Phone No-(079) 25631105, 25630438.

Lic No QAC/R91/4650

September 15, 2025.

To,
The Principal,
H 3 World School
Opp. Deo dap, Near Dutt Parisar,
Tragad, Ahmedabad.

Dear Sir,

We have analyzed your water samples collected on Dt. 02-09-2025 for the following **Chemical and Bacteriological** parameters. The analysis report is as hereunder.

Sr. No.	Parameter	Requirement (Acceptable Limit)	Permissible Limit in the Absence of Alternate Source	Sample Value
		As per IS-10500-2012		
A.	Organoleptic and Physical Parameters			
1	Colour, Hazen units, Max	5	15	0.1
2	pH value	6.5-8.5	No relaxation	7.20
3	Turbidity, NTU, Max	1	5	0.28
4	Total dissolved solids, mg/l, Max	500	2000	194
B.	General Parameters			
1	Total hardness (as CaCO ₃), mg/l, Max	200	600	120
2	Calcium (as Ca), mg/l, Max	75	200	28
3	Magnesium (as Mg), mg/l, Max	30	100	12.2
4	Chloride (as Cl), mg/l, Max	250	1000	25
5	Sulphate (as SO ₄) mg/l, Max	200	400	8.6
6	Total alkalinity (as CaCO ₃), mg/l, Max	200	600	120
7	Free residual chlorine, mg/l, Min	0.2	1.0	Nil
C.	Bacteriological Quality of Drinking Water			
1	Total Coliform bacteria, MPN/100 ml.	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	Not Detectable
2	E. coli, MPN/100 ml.	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	Not Detectable
Remarks:				

Remarks:

- The Central Laboratory, AMC, has collected the sample.
- The result contained in this report relate only to the sample material tested.
- The report is not being reproduce wholly or in part and cannot be used as evidence in the court of law and should not be used in any advertising media without our special permission in writing.

NOTE — It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned under 'acceptable' render the water not suitable, but still 'permissible limit in the absence of alternate source' in column 4, above which the sources will have to be rejected. May be tolerated in the absence of an alternative source but up to the limits indicated.

Dr. Hiren C. Mandalia
Scientist In-Charge